



WHEN TRUST MATTERS

Data-Driven Performance Standard Compliance Boosts Performance

IChemE Advances

Matthew Celnik, Chris Bell

20-21 October 2021



Welcome


Agenda

- Overview
- CRISP-DM
- Data/Models/Evaluation
- Other applicable solutions




Problem Overview

- Wanted to understand how systems were being operated on a day to day basis.
 - What equipment items were being inhibited routinely?
 - What systems were consistently operating outside of their design envelope?
- Reduced the cost incurred from verification test witnessing of PS criteria.
- Reduced the cost incurred from routine testing.
- Gain a holistic view of how their PS criteria was being met i.e. not just looking at staged testing when the system has been set up in preparation for a test.



CRISP-DM Sprint (cross-industry process for data mining)


- 1. Business understanding:** develop and understand the business/user requirements.
- 2. Data understanding:** review and understand the data; what anomalies are present in the data, and can it be used to provide insights?
- 3. Data preparation:** prepare the data to be analysed; remove anomalies, reshape as required, merge with other sources etc.
- 4. Model preparation:** develop algorithms and models to read the prepared data, and provide statistics, plots or insights to be evaluated.
- 5. Evaluation:** evaluate the model's effectiveness and ability to provide the answers required? Does it raise more questions that should be answered before proceeding further?





CRISP-DM Sprint

~1-2 weeks to develop an analytical tool



Data available

< DCS

04Feb2021-07Mar2021.xlsx →

07Mar2021-11Mar2021.xlsx →

11Mar2021-28Mar2021.xlsx →

12Apr2021-28Apr2021.xlsx →

Date_Time	Event Type	Category	Area	Node	Unit	Module	Module Descriptio	Attribute	State	Event Level	Desc1	Desc2
07/03/2021 12:24:02	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	LIT10007_C/CALC1	I/O Output Failure
07/03/2021 12:24:03	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	Error Cleared	I/O Output Failure
07/03/2021 12:24:10	EVENT	PROCESS	10_OIL_SEP	SER02	LIT10025	LIT10025_C	Calibration		ACTIVE	4-INFO	LIT10025_C/CALC1	I/O Output Failure
07/03/2021 12:24:11	EVENT	PROCESS	10_OIL_SEP	SER02	LIT10025	LIT10025_C	Calibration		ACTIVE	4-INFO	Error Cleared	I/O Output Failure
07/03/2021 12:24:12	ALARM	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALM	ACT/UNACK	07-SIS_PVBAD	MAINT	Loop Current Saturated
07/03/2021 12:24:12	EVENT	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALERTS		ACT/UNACK	Condition Set	Loop Current Saturated
07/03/2021 12:24:15	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	LIT10007_C/CALC1	I/O Output Failure
07/03/2021 12:24:16	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	Error Cleared	I/O Output Failure
07/03/2021 12:24:20	ALARM	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALM	INACT/UNACK	07-SIS_PVBAD	MAINT	Loop Current Saturated
07/03/2021 12:24:20	EVENT	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALERTS		ACT/UNACK	Condition Cleared	Loop Current Saturated
07/03/2021 12:24:23	EVENT	PROCESS	10_OIL_SEP	SER02	LIT10025	LIT10025_C	Calibration		ACTIVE	4-INFO	LIT10025_C/CALC1	I/O Output Failure
07/03/2021 12:24:25	EVENT	PROCESS	10_OIL_SEP	SER02	LIT10025	LIT10025_C	Calibration		ACTIVE	4-INFO	Error Cleared	I/O Output Failure
07/03/2021 12:24:29	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	LIT10007_C/CALC1	I/O Output Failure
07/03/2021 12:24:30	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	Error Cleared	I/O Output Failure
07/03/2021 12:24:37	EVENT	PROCESS	10_OIL_SEP	SER02	LIT10025	LIT10025_C	Calibration		ACTIVE	4-INFO	LIT10025_C/CALC1	I/O Output Failure
07/03/2021 12:24:38	EVENT	PROCESS	10_OIL_SEP	SER02	LIT10025	LIT10025_C	Calibration		ACTIVE	4-INFO	Error Cleared	I/O Output Failure
07/03/2021 12:24:42	ALARM	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALM	ACT/UNACK	07-SIS_PVBAD	MAINT	Loop Current Saturated
07/03/2021 12:24:42	EVENT	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALERTS		ACT/UNACK	Condition Set	Loop Current Saturated
07/03/2021 12:24:43	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	LIT10007_C/CALC1	I/O Output Failure
07/03/2021 12:24:44	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	Error Cleared	I/O Output Failure
07/03/2021 12:24:46	ALARM	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALM	INACT/UNACK	07-SIS_PVBAD	MAINT	Loop Current Saturated
07/03/2021 12:24:46	EVENT	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALERTS		ACT/UNACK	Condition Cleared	Loop Current Saturated
07/03/2021 12:24:50	EVENT	PROCESS	10_OIL_SEP	SER02	LIT10025	LIT10025_C	Calibration		ACTIVE	4-INFO	LIT10025_C/CALC1	I/O Output Failure
07/03/2021 12:24:52	EVENT	PROCESS	10_OIL_SEP	SER02	LIT10025	LIT10025_C	Calibration		ACTIVE	4-INFO	Error Cleared	I/O Output Failure
07/03/2021 12:24:56	EVENT	PROCESS	10_OIL_SEP	SER01	LIT10007	LIT10007_C	Calibration		ACTIVE	4-INFO	LIT10007_C/CALC1	I/O Output Failure
07/03/2021 12:24:56	ALARM	DEVICE	44_WATER_INJ	PCS04		PDIT-44510		MAINT_ALM	ACT/UNACK	07-SIS_PVBAD	MAINT	Loop Current Saturated

< Docs

NAME ^

Cause and Effects →

Operating Philosophies →

Perf_Std →

Asset F&G C&E		TAG	TRIP	LAYOUT #	LOOP	NOTE	IN	OUT	OUTLET (EFFICI)
SERVICE DESCRIPTION (CAUSE)									
FF&G Start-up Generator SIA-A-7000									
Point Flammable Gas Detected 120 LEL Ventilation Air Intake	650-79431	Low	71031						
Point Flammable Gas Detected 120 LEL Ventilation Air Intake	650-79431	Low	71031						
Point Flammable Gas Detected 120 LEL Ventilation Air Intake	650-79433	Low	71031						
Point Flammable Gas Detected 320 LEL Ventilation Air Intake	650-79431	High	71031						
Point Flammable Gas Detected 320 LEL Ventilation Air Intake	650-79431	High	71031						
Point Flammable Gas Detected 320 LEL Ventilation Air Intake	650-79433	High	71031						
Confirmed Flammable Gas Detected Ventilation Air Intake 320ppm	Table A19	Internal		13		X			
Enclosure IR3 Flame Detector	FD-70823	Alarm		14			X		
Enclosure IR3 Flame Detector	FD-70827	Alarm		14			X		
Confirmed Fire Detected 320ppm	Table A34	Internal		15		X			
Enclosure Heat Detector	HD-70834	Alarm		18		X			
Enclosure Heat Detector	HD-70835	Alarm		18		X			
Enclosure Heat Detector	HD-70836	Alarm		20		X			
Enclosure Heat Detector	HD-70836	Alarm		20		X			

Fire Pump Starting.

The fire pumps (P-8001A, P-8001B) shall start on demand following a signal from:

- Local Firewater Pump Control Panel
- Pushbutton on the Fire/Foam Pump Panel on the Fire & Gas Matrix
- 'Confirmed Fire' signal from the Fire & Gas Panel
- Operation of Manual Call Point (MAC)
- Firewater Ringmain low pressure switch

3.2 Firewater Control Panel Interface Signals

Hardwired signals to/from the firewater pump control panels and the FGS & LS7301.






Figure 5: Firewater Control Panel Interface



Inhibit & Alarm Log Miner

- High-level stats let us identify areas for deeper investigation. For example, short/long duration inhibits, failure patterns and daily routines which may deviate from procedure.



Event counts by hour of day

Date	0	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	Total	
02 January 2020																									9	
03 January 2020																										107
04 January 2020	12	8	3	2	4	2	5	1	5	26	3	2	8	2	7	13	5	4	3	12	3	3	1		134	
05 January 2020	9	1	4	2	2	5	17	21	16	24	3	12	16	1	8	2	2	7	1	14	15	8			194	
06 January 2020	4	5	2	2	2	3	4	6	9	2	9	1	11	8	1	13	4	2	9	1	1	2			101	
07 January 2020	1	1	7	2	1	1	3	46	3	15	9	8	3	1	1	3	1	3	2	7	7	4	2	2	133	
08 January 2020	9	6	9	13	15	5	18	14	314	166	56	23	17	14	31	17	53	15	9	7	6	10	10		847	
09 January 2020	12	7	6	5	5	6	10	28	8	7	9	11	5	12	11	14	16	13	5	6	7	10	5	10	283	
10 January 2020	8	11	17	8	3	4	8	24	35	43	29	26	3	5	49	43	18	34	11	7	1	5	14	24	569	
11 January 2020	12	4	7	4	5	7		2	9	6	2	7	2	2	15	2	3	1	1	1	1	4			98	
12 January 2020	1	3	7	2	1	4	4	11	3	2	5	11	3	10	8	2	2	7	6	8	8				108	
13 January 2020	3	1	2	7	7	7		3	2	11	9	3	11	4	2	6	14	11	2	2	39				126	
Total	181	163	148	160	164	207	200	275	589	441	322	237	213	273	340	247	325	228	170	288	264	169	123	164	5891	




Model Prep

Outcome

Events

Initiators



Model Prep

Create criteria mapping

InitiatorGroup	Votes-ooN	PerfStd	ResponseGroup	Criteria	CriteriaValue
Soft Hand Switch Pump A	1	SOAPAF01-5	Fire Pump A Running	Time	15
Soft Hand Switch Pump B	1	SOAPAF01-5	Fire Pump B Running	Time	15




Find Causes in DCS logs

InitiatorGroup	Tag
Soft Hand Switch Pump A	HS-80053
Soft Hand Switch Pump B	HS-80055



Find Effects in DCS logs

ResponseGroup	Tag
Fire Pump A Running	XZS-80112
Fire Pump B Running	XZS-80117





- Effect happened and achieved PS criteria as expected.
- Effect happened but failed to meet criteria.
- Effect never happened after cause.

- Need to ignore calibrations, bypasses maintenance lines etc.
- What if effect has already happened before cause is triggered?


Evaluation

- Looks good but views aren't useful to some staff
- Filters need customised for different users
- Data in table needs more details
- Is the data presented correct?
- Other systems to be onboarded ESD, HVAC etc.

Post-Evaluation




Final Product




Automatically Determine Performance Standard Compliance

- Cost & efficiency savings.
 - Reduce the need for planned assurance tests on systems.
 - Performing more verification work remotely.
 - Create more targeted plan for offshore inspection and witnessing.
- Monitor events during real operations & planned tests.
 - Planned tests may include unintended bias or be configured, differently to normal operations.
- Monitor features difficult to verify.
 - For example, reliability of fire pumps to engage on demand during normal operations (e.g. to maintain ring-main pressure).
- Monitor data from system cause and effects **not just performance standards.**
 - Ensure systems respond as expected.



Year	2020																					
	1			7			8			9			10			11			12			
Month	Passes	Fails	NoRe's	Passes	Fails	NoRe's	Passes	Fails	NoRe's	Passes	Fails	NoRe's	Passes	Fails	NoRe's	Passes	Fails	NoRe's	Passes	Fails	NoRe's	N
Active Fire Protection Systems-PS	1	7		3	3		8	22				1	12	16	5	3	10		6	8		
Emergency Shutdown-PS	1108	78	644	12		161	3579	136	893	569	67	113	2305	368	419	3168	340	1019	4054	565		
Fire and Gas Detection-PS			42	120	40	87			80	120	40	376	417	167	5811	119		1291				
FireWater Control and Operating Philosophy			1				3	1	2				1	1		2	1					
HVAC Enclosed Areas-PS	98	8		17			304		9	17			158	22	20	97	3		4	2		
Solan Fire & Gas Cause & Effects									1				185	10	117				16	8		
Temp Refuge and Muster-PS				350		70				350		70	700		140							



Automated Ex Inspection Reports

- Used by both the operator electrical TA and the ICP, this tool provides a visual summary of Ex inspections.
- System uses text analytics and rule set based on EI guidance and EN 60079-17 to:
 - Ensure inspection philosophy is followed.
 - Ensure failures are categorized and prioritized correctly.
 - Trend hazardous and significant failures
 - Trend failures by type i.e. earthing vs tagging
 - Trend failures by location on asset



Failure Rate Calculator & Maintenance Interval Optimiser

- Reads maintenance data as stored in Maximo/SAP
- Using real asset data
 - Text analytics (machine learning/AI) can be used to identify incorrect classified pass or failure records.
 - Text analytics can be used to identify child location failures.
 - Mean Time Between Failures (MTBF) can be calculated
 - Reliability on demand (RoD) can be calculated
 - Maintenance interval can be adjusted to optimise the RoD



IChemE Advances

Matthew Celnik & Chris Bell

Chris.Bell@dnv.com

www.dnv.com

